

5. 測定結果

5-1 室名 クリーンルーム

・測定は無人状態で行いました。

FED			
	時間 (分)	粒子数 (個/ft ³)	
		0.5 μm ≤	5.0 μm ≤
空調機 OFF		165180	1158
		168088	1139
		166657	1156
空調機 ON	1	143864	901
	2	81303	548
	3	49456	311
	4	32304	216
	5	20764	130
	6	14282	81
	7	8990	60
	8	5460	27
	9	3250	13
	10	1834	5
	11	1147	1
	12	880	4
	13	527	9
	14	326	4
	15	173	0
	16	137	1
	17	102	0
	18	72	0
	19	40	0
	20	21	0
	21	16	0

ISO			
	時間 (分)	粒子数 (個/m ³)	
		0.5 μm ≤	5.0 μm ≤
空調機 OFF		5834158	40901
		5936868	40229
		5886325	40830
空調機 ON	1	5081276	31823
	2	2871622	19355
	3	1746786	10985
	4	1140977	7629
	5	733384	4592
	6	504440	2861
	7	317527	2119
	8	192847	954
	9	114790	459
	10	64777	177
	11	40512	35
	12	31082	141
	13	18614	318
	14	11514	141
	15	6110	0
	16	4839	35
	17	3603	0
	18	2543	0
	19	1413	0
	20	742	0
	21	565	0

